

**RULES FOR ELECTRIC SERVICE
RULE 6 - AUXILIARY SERVICE
FOR NON-QUALIFYING FACILITIES**

(C)

A. APPLICATION

(1) Service to customers who have another source of power which can be substituted for Company's service for any of customer's operations. Service is supplied under the terms of this rule unless such other source of power is maintained solely for use in case of interruption of the Company's service. Service to Qualifying Facilities (QFs) is provided for under Rule 6A.

(2) Service is supplied only where Company has available the capacity and facilities adequate for the service and only under a contract for an initial term of one or more years under a general service rate schedule with measured demands. Bills for service are based on charges specified in the rate schedule, subject to a minimum charge as described in this rule.

(3) The customer's equipment may not be operated concurrently by means of service supplied by Company and by such other source of electric or mechanical power except upon written agreement setting forth the conditions of such operation.

(4) Customers selecting Rule 6 do not qualify for the Net Service provision of Rule 11.

B. MINIMUM CHARGE

The minimum monthly charge is the KW demand and KWH energy charges in the rate schedule for 100 hours use of the kilowatts of Reserved Capacity, plus the succeeding KW charge in the rate schedule for any kilowatts of the Billing KW in excess of the kilowatts of Reserved Capacity.

C. RESERVED CAPACITY

(1) When customer's entire power requirements exceed the capacity of such other source of power and no load limiter is installed, the Reserved Capacity is the rated capacity in kilowatts (at unity power factor) of customer's other source of power. In all other cases the Reserved Capacity is the average kilowatts, supplied during the single 15 minute period of maximum use during the current billing month or any of the preceding 11 months, but not less than the kilowatt setting of a load limiter, or, when no limiter is installed, not less than Company's estimate of the number of kilowatts of customer's entire power requirements as stated in the contract.

(2) The customer has the option of furnishing, installing, and maintaining a load limiter for service supplied by Company, which shall be approved, set, and sealed by Company. The limiter will be set at approximately the number of kilowatts of Reserved Capacity contracted for by the customer.

(C)

(THIS PAGE INTENTIONALLY LEFT BLANK)