

# RULES FOR ELECTRIC METER & SERVICE INSTALLATIONS



## RULE 25A

- (a) **Conditions for Providing Demand Pulses**
- (b) **Customer Owned Current Transformers Not Allowed**

### RULE 25A - CUSTOMER'S EQUIPMENT — ELECTRIC DEMAND CONTROL AND DATA COLLECTION EQUIPMENT

**a. Conditions for Providing Demand Pulses:**

PPL EU will provide electric demand pulses for customer-owned electric demand controllers and data collection equipment provided:

- (1) Customer enters into an agreement with PPL EU for demand pulse contacts.
- (2) Customer agrees to accept sole responsibility for the maintenance and replacement of the 1 ampere fuses installed in the PPL EU provided Connection Tie Box. See **Sketch #46**.

**b. Customer Owned Current Transformers Not Allowed:**

Installation of customer-owned current transformers or other load sensing devices for electric demand controllers is not permitted in 1) meter bases, 2) instrument transformer cabinets, or 3) instrument transformer and incoming line compartments located in customer's switchgear.

07-29-2011